



Plan View Regency Ballroom Sections 5, 6 and 7

Regency Ballroom Sections 5, 6, 7 - Ground Plan and Section View

Hyatt Regency - 265 Peachtree Street, NE Atlanta, GA 30309

**Engineering Notes**  
 Regency 7 Electrical Closet  
 #1 400 amp Three Phase Disconnect fused at 200 amps  
 #1 100 amp Single Phase Disconnect  
 Regency 6 Electrical Closet  
 #1 200 amp Three Phase Disconnect  
 #1 100 amp Single Phase Disconnect  
 100 Amp Marine Plug on Long wall of Regency 7 (see note)

**Rigging Notes**  
 Hatch Through Ceiling to Street

**Additional Notes**  
 Stage Remote Available for House Lights  
 Elevator, goes down to Street Level, Hotel uses it for chair storage, must request that it be available for use

SCALE: 1/4" = 1'  
 DATED: May 10, 1999  
 REVISED: May 18, 1999